

P.O. Box 554 | 2665 ZN Bleiswijk Brandpuntlaan Zuid 16 | 2665 NZ Bleiswijk The Netherlands +31 88 3473 723 nederland@efectis.com

## **CLASSIFICATION**

# CLASSIFICATION OF REACTION TO FIRE PERFORMANCE IN ACCORDANCE WITH EN 13501-1:2007+A1:2009

Classification no. 2016-Efectis-R000188

Sponsor **Avery Dennison** 

Willem Einthovenstraat 11 2342 BH OEGSTGEEST THE NETHERLANDS

Product name **Avery Dennison® MPI™ 3026 Supertack** 

Prepared by **Efectis Nederland BV** 

Notified body no. 1234

Author(s) C.C.M. Steinhage B.Sc.

A.J. Lock

Project number ENL-15-001399

Date of issue March 2016

Number of pages 5

No part of this publication may be reproduced and/or published without the previous written consent of Efectis Nederland. Submitting the report for inspection to parties who have a direct interest is permitted.





© 2016 Efectis Nederland BV Page 1 / 5



## 1. INTRODUCTION

This classification report defines the classification assigned to Avery Dennison® MPI<sup>™</sup> 3026 Supertack in accordance with the procedures given in EN 13501-1:2007+A1:2009.

### 2. DETAILS OF CLASSIFIED PRODUCT

### 2.1 GENERAL

The product, Avery Dennison® MPI<sup>TM</sup> 3026 Supertack, is defined as a wall covering.

## 2.2 MANUFACTURER

Avery Dennison Graphics & Reflective Solutions P.O. Box 28 2300 AA LEIDEN THE NETHERLANDS

## 2.3 PRODUCT DESCRIPTION

According to the sponsor the product is composed of:

• Film: 95 μm, matt white, self-adhesive monomeric calendered vinyl

Colour: matt white

Adhesive: permanent, acrylic based

• Backing paper: 125 g/m², clay coated kraft paper See Appendix 'Product data sheet' in the test reports.

In the end-use the product has a total thickness of approx. 95  $\mu$ m and a mass per unit area of approx. 140 g/m<sup>2</sup> (measured on the product).

## 3. REPORTS, RESULTS AND CRITERIA IN SUPPORT OF THIS CLASSIFICATION

## 3.1 REPORTS

Name of Laboratories	Name of sponsor	Report ref. no.	Test method
Efectis Nederland BV THE NETHERLANDS	Avery Dennison Graphics & Reflective Solutions THE NETHERLANDS	2016-Efectis-R000186 2016-Efectis-R000187	EN ISO 11925-2:2010 EN 13823:2014



## 3.2 TEST RESULTS

Test method and test number		No. tests	Results		
	Parameter		Continuous parameter - mean (m)	Compliance with parameters	
EN ISO 11925-2					
surface flame impingement	Fs ≤150 mm		6	20	-
	Ignition of filter	paper	O	-	Compliant
Edge flame Impingement	Fs ≤150 mm		6	15	-
	Ignition of filter	paper	O	-	Compliant
EN 13823					
	FIGRA <sub>0.2MJ</sub>	[W/s]		45	-
	FIGRA <sub>0.4MJ</sub>	[W/s]		0	-
	THR <sub>600s</sub>	[MJ]		0.7	-
	LFS < edge		•	-	Compliant
	SMOGRA	$[m^2/s^2]$	3	23	-
	TSP <sub>600s</sub>	[m <sup>2</sup> ]		36	-
	Flaming debris - flaming ≤ 10 s - flaming > 10 s			-	Compliant Compliant

## 3.3 CLASSIFICATION CRITERIA

Fire classification of construction products and building elements Excluding floorings and linear pipe thermal insulation products							
Classification criteria							
Class Test method(s)	В	С	D				
EN ISO 11925-2 Exposure = 30 s	$F_s \le 150$ mm within 60 s Ignition of the paper in EN ISO 11925-2 results in a d2 classification.						
EN 13823	FIGRA <sub>0.2 MJ</sub> $\leq$ 120 W/s LFS $<$ edge of specimen THR <sub>600s</sub> $\leq$ 7.5 MJ	FIGRA <sub>0.4 MJ</sub> $\leq$ 250 W/s LFS $<$ edge of specimen THR <sub>600s</sub> $\leq$ 15 MJ	$FIGRA_{0.4 \text{ MJ}} \leq 750 \text{ W/s}$				
Additional classification							
Smoke production	$s1 = SMOGRA \le 30 \text{ m}^2/\text{s}^2 \text{ and } TSP_{600s} \le 50 \text{ m}^2$ ; $s2 = SMOGRA \le 180 \text{ m}^2/\text{s}^2 \text{ and } TSP_{600s} \le 200 \text{ m}^2$ ; s3 = not  s1  or  s2						
Flaming Droplets/particles	O = no flaming droplets/ particles in EN 13823 within 600 s; 1 = no flaming droplets/ particles persisting longer than 10 s in EN 13823 within 600 s; 2 = not d0 or d1.						



### 4. CLASSIFICATION AND FIELD OF APPLICATION

### 4.1 REFERENCE OF CLASSIFICATION

This classification has been carried out in accordance with clause 11 of EN 13501-1:2007+ A1:2009.

### 4.2 CLASSIFICATION

The product, Avery Dennison® MPI<sup>™</sup> 3026 Supertack, in relation to its reaction to fire behaviour is classified:

В

The additional classification in relation to smoke production is:

**s**1

The additional classification in relation to flaming droplets / particles is:

d012

# Reaction to fire classification: B - s1, d0

## 4.3 FIELD OF APPLICATION

This classification is valid for the following product parameters:

Thickness 95 µm

Surface density Approx. 140 g/m<sup>2</sup>

Other properties Colour: matt white

This classification is valid for the following end use applications:

Substrate Non-combustible

(class A1 according to EN 13238:2010)

Air gap Including air gap

Methods and means of fixing Using the adhesive of the product

Joints Vertical only

Other aspects of end use

conditions

Wall covering

## 4.4 DURATION OF THE VALIDITY OF THIS CLASSIFICATION REPORT

There are no limitations in time on the validity of this report.



# **CLASSIFICATION**



## LIMITATIONS

This classification document does not represent type approval or certification of the product.

C.C.M. Steinhage B.Sc.

Project leader reaction to fire

A.J. Lock

Project leader reaction to fire